



THE CITY OF SAN DIEGO

## Fire-Rescue Department

### Sprinkler Policies Policy FS – 0409

---

#### ***Inspector's Test Valve Location***

Inspector's test valves should be located in the farthest most hydraulically remote area of the sprinkler system. The exact location shall be approved at plan review.

Exception: Inspector's test valves may be supplied from pipe adjacent to the riser in multi-story buildings.